

Central Valley Regional Water Quality Control Board

Monitoring Report Submittal Transmittal Form

Attn: Guy Childs (916) 464-4648
Central Valley Regional Water Quality Control Board
11020 Sun Center Drive #200
Rancho Cordova, CA 95670-6114

Discharger: Ironhouse Sanitary District
Name of Facility: Ironhouse Wastewater Treatment Facility
WDRs Order Number: R5-2013-0010
WDID: 5B070105005
County: Contra Costa

I am hereby submitting to the Central Valley Water Board the following information:

Check all that apply:

Monthly Monitoring Report for the month of _____

1st / 2nd / 3rd / 4th (**circle one**) Quarterly Monitoring Report for the year of _____

1st / 2nd (**circle one**) Semi-annual Monitoring Report for the year _____

Annual Monitoring Report for the year 2019

Violation Notification

During the monitoring period, there were / were not (circle one) any violations of the WDRs.

1. The violations were:

- Groundwater Well MNLND-02 exceeded the recommended nitrate limit of 10 mg/L on February 25, 2019.

2. Have the violations been corrected? Yes / No. If no, what will be done to correct the violations:

- The high concentration observed in MNLND-02 during Q1 2019 appears to be an anomalous event. Continued quarterly monitoring demonstrates the well returned to compliance for the remainder of the monitoring year.

Certification Statement

"I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment."

Signature:  _____

Phone: 209-262-8008

Printed Name: Chris Christean

Date: January 30, 2020

