

ADDENDUM NO. 2

DATE: June 13, 2019

PROJECT: ISD Old Town Pipeline Improvement Project

Oakley, California

FROM: Ironhouse Sanitary District

450 Walnut Meadows Drive

Oakley, CA 94561

TO: Bidders

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

The following changes are made with supporting attachments:

1. REVISED specification 005200 1.04 A. Completion of Work – Contractor shall achieve Substantial Completion of the entire Work within: Base Project = 315 Calendar days / Base Project plus Additive Bid Project = 420 Calendar days
2. REVISED specification 02736, 1.03 A. Submittals – Furnish one color video recording on DVD in “Pipetech Inspection Software” format or similar, with audio, for each section of main sewer or building sewer inspected, and electronic images of all photographs taken during the inspection.
3. REVISED specification 02736, 1.03 D. Submittals – Furnish a report and photos indicating the location of all laterals and connections encountered, the location of any breaks, obstructions, offsets, high points, sags or other major defects, and the condition of manholes. All entries in the report for Post Construction CCTV shall be in NASSCO PACP format.

ADDITIONAL RESPONSE TO QUESTIONS RECEIVED DURING PRE-BID MEETING

1. Question: Will Diablo Water District have an inspector present on-site during work on Main Street due to proximity of existing water main to existing sewer main? Response: Yes, Diablo Water will have an inspector on-site during construction at Main Street. Inspection activities will be in a periodic basis.

END OF ADDENDUM NO. 2

Attach this Addendum No. 2 to the Bid Documents before submitting your bid.

ACCEPTED BY:

Dated: _____ day of _____, 2019.

Name of Contractor: _____

Signature of Authorized Officer: _____